

UNITED ANALYTICAL SERVICES, INC.

1429 Centre Circle Drive
Downers Grove, IL 60515
Phone: (630) 691-8271
Fax: (630) 691-1819
E-Mail: uasinc@uas1.com

December 12, 2017

Board of Education
Glen Ellyn School District #41
793 N. Main Street
Glen Ellyn, Illinois 60137

UAS Project #1798590-01

Attn: Mr. Dave Scarmardo, Director of Buildings & Grounds
Re: Summary of Findings - Lead in Drinking Water Sampling & Lab Analysis
Glen Ellyn School District #41
Hadley Junior High School
240 Hawthorne Blvd., Glen Ellyn, Illinois 60137
November 16, 2017

Dear Mr. Scarmardo:

United Analytical Services, Inc. (UAS) prepared this executive summary of findings for the drinking water sampling performed at Glen Ellyn School District #41's Hadley Junior High School located at 240 Hawthorn Blvd. in Glen Ellyn, Illinois on November 16, 2017. The current testing involved collecting drinking water samples from thirty-seven (37) of the drinking water sources/locations throughout the school facility that are accessible to the Students, Faculty and Staff, with subsequent laboratory analysis for the presence of Lead. Including 1st draw and 2nd draw samples at each of the drinking water sources, a total of seventy-four (74) water samples were collected during this current assessment.

It should be noted that the current sampling at this Glen Ellyn School District #41 school facility included the IDPH required drinking water sources within facility, as well as several non-required drinking water and/or potable water sources within the school building.

The laboratory results reveal that the reported concentrations for thirty-seven (37) of the thirty-seven (37) drinking water samples resulted in concentrations below the IDPH public notification/communication target level of 5 µg Lead/L. Zero (0) of the samples revealed a drinking water concentration above the IDPH public notification/communication target level of 5 µg Lead/L.

SAMPLING REQUIREMENTS AND METHODOLOGY -

The current sampling and reporting followed the Illinois Public Act 99-0922 requirements. Following the IDPH requirements and reporting, it should be noted that UAS performed and provided the services noted below, including, but not limited to, the following:

1. The current testing and analysis was limited only to those thirty-seven (37) locations/sources noted.
2. UAS provided fixture/source identifiers for each of the sources/locations identified with alphanumeric identifiers for each fixture and sample.
3. UAS utilized sampling media (250 mL sample bottles) obtained from a State of Illinois Environmental Protection Agency (IEPA) accredited laboratory, labeled all sampling bottles with the alphanumeric identifiers and prepared a Chain of Custody form for samples.
4. The IEPA accredited laboratory that UAS utilized to perform the laboratory analysis for this project was Pace Analytical Services, LLC (Pace) of Minneapolis, MN. Pace is recognized by the IEPA as NELAP-Recognized Environmental Laboratory for Lead in Drinking Water. A copy of the SLI accreditation for the approved method is attached. UAS confirmed with SLI, that the IDPH required minimum reporting limit (MRL) and significant digits requested by IDPH could be utilized and documented. The MRL identified by IDPH, and utilized for this assessment was 2.00 µg Lead/L, or lower.
5. Following confirmation from Glen Ellyn School District #41 (S.D. #41) that each of the target drinking water sources/systems had been allowed a mandated stagnation period of eight (8) to eighteen (18) hours, UAS collected the required 1st Draw and 2nd Draw (30 second flush) drinking water samples from each drinking water fixture/source identified by S.D. #41. S.D. #41 reported that the last use of any of the sources/fixtures in the school was 8:00 p.m. on November 15, 2017, following a day of typical school occupancy and usage within the facility. The sample collection by UAS began at 5:00 a.m. on November 16, 2017 and was completed prior to any water use within the building.
6. UAS completed and compiled Chain of Custody forms for the school building samples.
7. UAS submitted the samples to Pace following strict Chain of Custody protocols.
8. UAS compiled this final summary report with results for this school using IDPH's guidance for reporting, data and information spreadsheet to ensure consistency and reliability.
10. All sampling, documentation and reporting was performed under the direct supervision of an Illinois Department of Public Health (IDPH) licensed Lead Inspector/Risk Assessor.

IDPH REPORTING & PUBLIC NOTIFICATION -

As required, IDPH Reporting and Public Notification requirements shall be the responsibility of Glen Ellyn School District #41. Please note the following: Illinois Public Act 099-0922: Within seven (7) days of receipt of these test results, the district/school must email all test results to IDPH. If any of the samples taken in the school exceed 5 parts per billion (µg/L), the school district or chief school administrator, or the designee of the school district or chief school administrator, shall promptly provide an individual notification of the sampling results, via written or electronic communication, to the parents or legal guardians of all enrolled students and include the following information: the corresponding sampling location within the school building and the United States Environmental Protection Agency's website for information about lead in drinking water. If any of the samples taken at the school are at or below 5 parts per billion (µg/L), notification may be made by posting on the schools website.

TEST RESULTS / SUMMARY OF FINDINGS-

The test results are noted in the attached Spreadsheet and Analytical Laboratory Reports. The current testing and analysis was limited only to those thirty-seven (37) locations/sources noted. Review of the current testing laboratory data reveals the following:

The results from thirty-six (36) of the thirty-seven (37) locations/sources reveled concentrations below both the IDPH mitigation strategies lower limit of 2 ppb, and below the IDPH public notification/communication target level of 5 µg Lead/L.

One (1) of the thirty-seven (37) locations/sources reported a concentration at/above the IDPH mitigation strategies lower limit of 2 ppb, but below the IDPH public notification/communication target level of 5 µg Lead/L.

Zero (0) of the thirty-seven (37) locations/sources revealed a drinking water concentration above the IDPH public notification/communication target level of 5 µg Lead/L.

Pursuant to Public Act 99-0922, the Illinois Plumbing Licensing Law (225 ILCS 320/35.5), the IDPH is required to provide guidance to schools concerning mitigation of hazards discovered by testing for lead in water. While Section 35.5 does not require mitigation, IDPH is requiring the mitigation strategies and requirements contained in their Guidance Document for Mitigating Lead in Schools (copy attached) to be followed for all plumbing fixtures identified with any level of lead. IDPH further notes that mitigation strategies should continue until subsequent testing indicates no lead is present in water.

RECOMMENDATIONS -

At this time, UAS recommends the following:

1. Along with their standard water programs, Glen Ellyn School District #41 should follow the IDPH reporting requirements, as well as the mitigation strategies and requirements contained in their Guidance Document for Mitigating Lead in Schools (copy attached) for the sources, locations and fixtures that were identified with lead greater than 2 parts per billion (µg/L). IDPH further notes that mitigation strategies should continue until subsequent testing indicates no lead (<2.00 ppb) is present in water. While none were revealed, it should be noted that any source, location and fixture that was identified with lead of 5 parts per billion (µg/L) or greater should be taken “off-line”, either permanently, or until such time that mitigation and subsequent testing demonstrate that lead levels are within acceptable IDPH limits.
2. Glen Ellyn School District #41 should provide this report and results to IDPH in accordance with Illinois Public Act 099-0922.
3. Pursuant to Public Act 99-0922, the Illinois Plumbing Licensing Law (225 ILCS 320/35.5), the IDPH is required to provide guidance to schools concerning mitigation of hazards discovered by testing for lead in water. While Section 35.5 does not require mitigation, IDPH is requiring the mitigation strategies and requirements contained in their Guidance Document for Mitigating Lead in Schools (copy attached) to be followed for all plumbing fixtures identified with any level

Mr. Dave Scarmardo, Director of Buildings & Grounds
Summary of Findings - Lead in Drinking Water Sampling & Lab Analysis
Glen Ellyn School District #41 - Hadley Junior High School
240 Hawthorne Blvd., Glen Ellyn, Illinois 60137

December 12, 2017

Page – 4 –

of lead. IDPH further notes that mitigation strategies should continue until subsequent testing indicates no lead (i.e. <2.00 ppb) is present in water.

Thank you for the continued opportunity to be of service to Glen Ellyn School District #41. If you have any questions regarding this information, please do not hesitate to contact our office.

Sincerely,
UNITED ANALYTICAL SERVICES, INC.



Thad Daniels
Director of Field Services
Lead Risk Assessor (IL 001047)

attachments: IDPH Spreadsheet Summary of Lead in Drinking Water
12/06/17 Laboratory Report & COCs
IDPH Mitigation Strategies
UAS' Inspector/Sample Collector License & Accreditation
Pace Laboratory Accreditation

cc: Kevin E. Aikman, Ph.D., CIH, FAIHA (UAS)

S:\TD\IHReports\SD41.Hadley JHS.1798590-01.Report

December 06, 2017

Thad Daniels
United Analytical Services, Inc.
1429 Centre Circle Drive
Downers Grove, IL 60515


RE: Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Dear Thad Daniels:

Enclosed are the analytical results for sample(s) received by the laboratory on November 22, 2017. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Sylvia Hunter
sylvia.hunter@pacelabs.com
1(612)607-1700
Project Manager

Enclosures

cc: Mr. Thad Daniels, United Analytical Services, Inc



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Minnesota Certification IDs

1700 Elm Street SE, Suite 200, Minneapolis, MN 55414-2485
A2LA Certification #: 2926.01
Alabama Certification #: 40770
Alaska Contaminated Sites Certification #: 17-009
Alaska DW Certification #: MN00064
Arizona Certification #: AZ0014
Arkansas Certification #: 88-0680
California Certification #: 2929
CNMI Saipan Certification #: MP0003
Colorado Certification #: MN00064
Connecticut Certification #: PH-0256
EPA Region 8+Wyoming DW Certification #: via MN 027-053-137
Florida Certification #: E87605
Georgia Certification #: 959
Guam EPA Certification #: MN00064
Hawaii Certification #: MN00064
Idaho Certification #: MN00064
Illinois Certification #: 200011
Indiana Certification #: C-MN-01
Iowa Certification #: 368
Kansas Certification #: E-10167
Kentucky DW Certification #: 90062
Kentucky WW Certification #: 90062
Louisiana DEQ Certification #: 03086
Louisiana DW Certification #: MN00064
Maine Certification #: MN00064
Maryland Certification #: 322
Massachusetts Certification #: M-MN064

Michigan Certification #: 9909
Minnesota Certification #: 027-053-137
Mississippi Certification #: MN00064
Montana Certification #: CERT0092
Nebraska Certification #: NE-OS-18-06
Nevada Certification #: MN00064
New Hampshire Certification #: 2081
New Jersey Certification #: MN002
New York Certification #: 11647
North Carolina DW Certification #: 27700
North Carolina WW Certification #: 530
North Dakota Certification #: R-036
Ohio DW Certification #: 41244
Ohio VAP Certification #: CL101
Oklahoma Certification #: 9507
Oregon NwTPH Certification #: MN300001
Oregon Secondary Certification #: MN200001
Pennsylvania Certification #: 68-00563
Puerto Rico Certification #: MN00064
South Carolina Certification #: 74003001
Tennessee Certification #: TN02818
Texas Certification #: T104704192
Utah Certification #: MN00064
Virginia Certification #: 460163
Washington Certification #: C486
West Virginia DW Certification #: 9952 C
West Virginia DEP Certification #: 382
Wisconsin Certification #: 999407970

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10412132001	HS-01a First Floor Office DWC	Water	11/16/17 05:00	11/22/17 11:30
10412132002	HS-01b First Floor Office DWC	Water	11/16/17 05:00	11/22/17 11:30
10412132003	HS-02a First Floor Office BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132004	HS-02b First Floor Office BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132005	HS-03a Corridor 10 DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132006	HS-03b Corridor 10 DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132007	HS-04a Corridor 10 DWC BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132008	HS-04b Corridor 10 DWC BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132009	HS-05a Corridor 10 DWC Right	Water	11/16/17 05:00	11/22/17 11:30
10412132010	HS-05b Corridor 10 DWC Right	Water	11/16/17 05:00	11/22/17 11:30
10412132011	HS-06a Classroom 144 Sink	Water	11/16/17 05:00	11/22/17 11:30
10412132012	HS-06b Classroom 144 Sink	Water	11/16/17 05:00	11/22/17 11:30
10412132013	HS-07a Classroom 145 Sink	Water	11/16/17 05:00	11/22/17 11:30
10412132014	HS-07b Classroom 145 Sink	Water	11/16/17 05:00	11/22/17 11:30
10412132015	HS-08a Classroom 147 Sink	Water	11/16/17 05:00	11/22/17 11:30
10412132016	HS-08b Classroom 147 Sink	Water	11/16/17 05:00	11/22/17 11:30
10412132017	HS-09a Lunchroom West DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132018	HS-09b Lunchroom West DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132019	HS-10a Lunchroom West DWC R	Water	11/16/17 05:00	11/22/17 11:30
10412132020	HS-10b Lunchroom West DWC R	Water	11/16/17 05:00	11/22/17 11:30
10412132021	HS-11a Lunchroom West BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132022	HS-11b Lunchroom West BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132023	HS-12a Lunchroom East DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132024	HS-12b Lunchroom East DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132025	HS-13a Lunchroom East BFS Left	Water	11/16/17 05:00	11/22/17 11:30
10412132026	HS-13b Lunchroom East BFS Left	Water	11/16/17 05:00	11/22/17 11:30
10412132027	HS-14a Lunchroom East DWC R	Water	11/16/17 05:00	11/22/17 11:30
10412132028	HS-14b Lunchroom East DWC R	Water	11/16/17 05:00	11/22/17 11:30
10412132029	HS-15a Lunchroom East BFS R	Water	11/16/17 05:00	11/22/17 11:30
10412132030	HS-15b Lunchroom East BFS R	Water	11/16/17 05:00	11/22/17 11:30
10412132031	HS-16a Kitchen Sink	Water	11/16/17 05:00	11/22/17 11:30
10412132032	HS-16b Kitchen Sink	Water	11/16/17 05:00	11/22/17 11:30
10412132033	HS-17a Teacher's LunchroomSink	Water	11/16/17 05:00	11/22/17 11:30
10412132034	HS-17b Teacher's LunchroomSink	Water	11/16/17 05:00	11/22/17 11:30
10412132035	HS-18a Corridor 1 DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132036	HS-18b Corridor 1 DWC Left	Water	11/16/17 05:00	11/22/17 11:30

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10412132037	HS-19a Corridor 1 BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132038	HS-19b Corridor 1 BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132039	HS-20a Corridor 1 DWC Right	Water	11/16/17 05:00	11/22/17 11:30
10412132040	HS-20b Corridor 1 DWC Right	Water	11/16/17 05:00	11/22/17 11:30
10412132041	HS-21a Corridor 20 DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132042	HS-21b Corridor 20 DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132043	HS-22a Corridor 20 DWC Right	Water	11/16/17 05:00	11/22/17 11:30
10412132044	HS-22b Corridor 20 DWC Right	Water	11/16/17 05:00	11/22/17 11:30
10412132045	HS-23a Corridor 20 BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132046	HS-23b Corridor 20 BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132047	HS-24a Corridor 17 DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132048	HS-24b Corridor 17 DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132049	HS-25a Corridor 17 DWC Right	Water	11/16/17 05:00	11/22/17 11:30
10412132050	HS-25b Corridor 17 DWC Right	Water	11/16/17 05:00	11/22/17 11:30
10412132051	HS-26a Corridor 17 BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132052	HS-26b Corridor 17 BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132053	HS-27a Basement Corridor DWC L	Water	11/16/17 05:00	11/22/17 11:30
10412132054	HS-27b Basement Corridor DWC L	Water	11/16/17 05:00	11/22/17 11:30
10412132055	HS-28a Basement Corridor BFS L	Water	11/16/17 05:00	11/22/17 11:30
10412132056	HS-28b Basement Corridor BFS L	Water	11/16/17 05:00	11/22/17 11:30
10412132057	HS-29a Basement Corridor DWC R	Water	11/16/17 05:00	11/22/17 11:30
10412132058	HS-29b Basement Corridor DWC R	Water	11/16/17 05:00	11/22/17 11:30
10412132059	HS-30a Basement Corridor BFS R	Water	11/16/17 05:00	11/22/17 11:30
10412132060	HS-30b Basement Corridor BFS R	Water	11/16/17 05:00	11/22/17 11:30
10412132061	HS-31a Corridor 14 DWC West	Water	11/16/17 05:00	11/22/17 11:30
10412132062	HS-31b Corridor 14 DWC West	Water	11/16/17 05:00	11/22/17 11:30
10412132063	HS-32a Corridor 14 BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132064	HS-32b Corridor 14 BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132065	HS-33a Corridor 14 DWC East	Water	11/16/17 05:00	11/22/17 11:30
10412132066	HS-33b Corridor 14 DWC East	Water	11/16/17 05:00	11/22/17 11:30
10412132067	HS-34a Gym BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132068	HS-34b Gym BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132069	HS-35a Corridor 11 DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132070	HS-35b Corridor 11 DWC Left	Water	11/16/17 05:00	11/22/17 11:30
10412132071	HS-36a Corridor 11 BFS	Water	11/16/17 05:00	11/22/17 11:30
10412132072	HS-36b Corridor 11 BFS	Water	11/16/17 05:00	11/22/17 11:30

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10412132073	HS-37a Corridor 11 DWC Right	Water	11/16/17 05:00	11/22/17 11:30
10412132074	HS-37b Corridor 11 DWC Right	Water	11/16/17 05:00	11/22/17 11:30

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10412132001	HS-01a First Floor Office DWC	EPA 200.8	WBS	1	PASI-M
10412132002	HS-01b First Floor Office DWC	EPA 200.8	WBS	1	PASI-M
10412132003	HS-02a First Floor Office BFS	EPA 200.8	WBS	1	PASI-M
10412132004	HS-02b First Floor Office BFS	EPA 200.8	WBS	1	PASI-M
10412132005	HS-03a Corridor 10 DWC Left	EPA 200.8	WBS	1	PASI-M
10412132006	HS-03b Corridor 10 DWC Left	EPA 200.8	WBS	1	PASI-M
10412132007	HS-04a Corridor 10 DWC BFS	EPA 200.8	WBS	1	PASI-M
10412132008	HS-04b Corridor 10 DWC BFS	EPA 200.8	WBS	1	PASI-M
10412132009	HS-05a Corridor 10 DWC Right	EPA 200.8	WBS	1	PASI-M
10412132010	HS-05b Corridor 10 DWC Right	EPA 200.8	WBS	1	PASI-M
10412132011	HS-06a Classroom 144 Sink	EPA 200.8	WBS	1	PASI-M
10412132012	HS-06b Classroom 144 Sink	EPA 200.8	WBS	1	PASI-M
10412132013	HS-07a Classroom 145 Sink	EPA 200.8	WBS	1	PASI-M
10412132014	HS-07b Classroom 145 Sink	EPA 200.8	WBS	1	PASI-M
10412132015	HS-08a Classroom 147 Sink	EPA 200.8	WBS	1	PASI-M
10412132016	HS-08b Classroom 147 Sink	EPA 200.8	WBS	1	PASI-M
10412132017	HS-09a Lunchroom West DWC Left	EPA 200.8	WBS	1	PASI-M
10412132018	HS-09b Lunchroom West DWC Left	EPA 200.8	WBS	1	PASI-M
10412132019	HS-10a Lunchroom West DWC R	EPA 200.8	WBS	1	PASI-M
10412132020	HS-10b Lunchroom West DWC R	EPA 200.8	WBS	1	PASI-M
10412132021	HS-11a Lunchroom West BFS	EPA 200.8	WBS	1	PASI-M
10412132022	HS-11b Lunchroom West BFS	EPA 200.8	WBS	1	PASI-M
10412132023	HS-12a Lunchroom East DWC Left	EPA 200.8	WBS	1	PASI-M
10412132024	HS-12b Lunchroom East DWC Left	EPA 200.8	WBS	1	PASI-M
10412132025	HS-13a Lunchroom East BFS Left	EPA 200.8	WBS	1	PASI-M
10412132026	HS-13b Lunchroom East BFS Left	EPA 200.8	WBS	1	PASI-M
10412132027	HS-14a Lunchroom East DWC R	EPA 200.8	WBS	1	PASI-M
10412132028	HS-14b Lunchroom East DWC R	EPA 200.8	WBS	1	PASI-M
10412132029	HS-15a Lunchroom East BFS R	EPA 200.8	WBS	1	PASI-M
10412132030	HS-15b Lunchroom East BFS R	EPA 200.8	WBS	1	PASI-M
10412132031	HS-16a Kitchen Sink	EPA 200.8	WBS	1	PASI-M
10412132032	HS-16b Kitchen Sink	EPA 200.8	WBS	1	PASI-M
10412132033	HS-17a Teacher's LunchroomSink	EPA 200.8	WBS	1	PASI-M
10412132034	HS-17b Teacher's LunchroomSink	EPA 200.8	WBS	1	PASI-M
10412132035	HS-18a Corridor 1 DWC Left	EPA 200.8	WBS	1	PASI-M
10412132036	HS-18b Corridor 1 DWC Left	EPA 200.8	WBS	1	PASI-M
10412132037	HS-19a Corridor 1 BFS	EPA 200.8	WBS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10412132038	HS-19b Corridor 1 BFS	EPA 200.8	WBS	1	PASI-M
10412132039	HS-20a Corridor 1 DWC Right	EPA 200.8	WBS	1	PASI-M
10412132040	HS-20b Corridor 1 DWC Right	EPA 200.8	WBS	1	PASI-M
10412132041	HS-21a Corridor 20 DWC Left	EPA 200.8	WBS	1	PASI-M
10412132042	HS-21b Corridor 20 DWC Left	EPA 200.8	WBS	1	PASI-M
10412132043	HS-22a Corridor 20 DWC Right	EPA 200.8	WBS	1	PASI-M
10412132044	HS-22b Corridor 20 DWC Right	EPA 200.8	WBS	1	PASI-M
10412132045	HS-23a Corridor 20 BFS	EPA 200.8	WBS	1	PASI-M
10412132046	HS-23b Corridor 20 BFS	EPA 200.8	WBS	1	PASI-M
10412132047	HS-24a Corridor 17 DWC Left	EPA 200.8	WBS	1	PASI-M
10412132048	HS-24b Corridor 17 DWC Left	EPA 200.8	WBS	1	PASI-M
10412132049	HS-25a Corridor 17 DWC Right	EPA 200.8	WBS	1	PASI-M
10412132050	HS-25b Corridor 17 DWC Right	EPA 200.8	WBS	1	PASI-M
10412132051	HS-26a Corridor 17 BFS	EPA 200.8	WBS	1	PASI-M
10412132052	HS-26b Corridor 17 BFS	EPA 200.8	WBS	1	PASI-M
10412132053	HS-27a Basement Corridor DWC L	EPA 200.8	WBS	1	PASI-M
10412132054	HS-27b Basement Corridor DWC L	EPA 200.8	WBS	1	PASI-M
10412132055	HS-28a Basement Corridor BFS L	EPA 200.8	WBS	1	PASI-M
10412132056	HS-28b Basement Corridor BFS L	EPA 200.8	WBS	1	PASI-M
10412132057	HS-29a Basement Corridor DWC R	EPA 200.8	WBS	1	PASI-M
10412132058	HS-29b Basement Corridor DWC R	EPA 200.8	WBS	1	PASI-M
10412132059	HS-30a Basement Corridor BFS R	EPA 200.8	WBS	1	PASI-M
10412132060	HS-30b Basement Corridor BFS R	EPA 200.8	WBS	1	PASI-M
10412132061	HS-31a Corridor 14 DWC West	EPA 200.8	WBS	1	PASI-M
10412132062	HS-31b Corridor 14 DWC West	EPA 200.8	WBS	1	PASI-M
10412132063	HS-32a Corridor 14 BFS	EPA 200.8	WBS	1	PASI-M
10412132064	HS-32b Corridor 14 BFS	EPA 200.8	WBS	1	PASI-M
10412132065	HS-33a Corridor 14 DWC East	EPA 200.8	WBS	1	PASI-M
10412132066	HS-33b Corridor 14 DWC East	EPA 200.8	WBS	1	PASI-M
10412132067	HS-34a Gym BFS	EPA 200.8	WBS	1	PASI-M
10412132068	HS-34b Gym BFS	EPA 200.8	WBS	1	PASI-M
10412132069	HS-35a Corridor 11 DWC Left	EPA 200.8	WBS	1	PASI-M
10412132070	HS-35b Corridor 11 DWC Left	EPA 200.8	WBS	1	PASI-M
10412132071	HS-36a Corridor 11 BFS	EPA 200.8	WBS	1	PASI-M
10412132072	HS-36b Corridor 11 BFS	EPA 200.8	WBS	1	PASI-M
10412132073	HS-37a Corridor 11 DWC Right	EPA 200.8	WBS	1	PASI-M
10412132074	HS-37b Corridor 11 DWC Right	EPA 200.8	WBS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: **HS-01a First Floor Office DW** Lab ID: **10412132001** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:03	7439-92-1	

Sample: **HS-01b First Floor Office DW** Lab ID: **10412132002** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:11	7439-92-1	

Sample: **HS-02a First Floor Office BFS** Lab ID: **10412132003** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:12	7439-92-1	

Sample: **HS-02b First Floor Office BFS** Lab ID: **10412132004** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:17	7439-92-1	

Sample: **HS-03a Corridor 10 DWC Left** Lab ID: **10412132005** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: HS-03b Corridor 10 DWC Lab ID: 10412132006 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
Left

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:20	7439-92-1	

Sample: HS-04a Corridor 10 DWC Lab ID: 10412132007 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
BFS

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:21	7439-92-1	

Sample: HS-04b Corridor 10 DWC Lab ID: 10412132008 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
BFS

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:23	7439-92-1	

Sample: HS-05a Corridor 10 DWC Lab ID: 10412132009 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
Right

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	0.23	ug/L	0.10	0.010	1		11/30/17 23:24	7439-92-1	

Sample: HS-05b Corridor 10 DWC Lab ID: 10412132010 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
Right

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	0.23	ug/L	0.10	0.010	1		11/30/17 23:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: HS-06a Classroom 144 Sink Lab ID: 10412132011 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	0.61	ug/L	0.10	0.010	1		11/30/17 23:26	7439-92-1	

Sample: HS-06b Classroom 144 Sink Lab ID: 10412132012 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	0.19	ug/L	0.10	0.010	1		11/30/17 23:29	7439-92-1	

Sample: HS-07a Classroom 145 Sink Lab ID: 10412132013 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	2.3	ug/L	0.10	0.010	1		11/30/17 23:34	7439-92-1	

Sample: HS-07b Classroom 145 Sink Lab ID: 10412132014 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	0.12	ug/L	0.10	0.010	1		11/30/17 23:35	7439-92-1	

Sample: HS-08a Classroom 147 Sink Lab ID: 10412132015 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	0.24	ug/L	0.10	0.010	1		11/30/17 23:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: HS-08b Classroom 147 Sink Lab ID: 10412132016 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.13	ug/L	0.10	0.010	1		11/30/17 23:38	7439-92-1	

Sample: HS-09a Lunchroom West DWC Left Lab ID: 10412132017 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:39	7439-92-1	

Sample: HS-09b Lunchroom West DWC Left Lab ID: 10412132018 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:40	7439-92-1	

Sample: HS-10a Lunchroom West DWC R Lab ID: 10412132019 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:42	7439-92-1	

Sample: HS-10b Lunchroom West DWC R Lab ID: 10412132020 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	0.010	1		11/30/17 23:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: **HS-11a Lunchroom West BFS** Lab ID: **10412132021** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:28	7439-92-1	

Sample: **HS-11b Lunchroom West BFS** Lab ID: **10412132022** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:33	7439-92-1	

Sample: **HS-12a Lunchroom East DWC Left** Lab ID: **10412132023** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:34	7439-92-1	

Sample: **HS-12b Lunchroom East DWC Left** Lab ID: **10412132024** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:36	7439-92-1	

Sample: **HS-13a Lunchroom East BFS Left** Lab ID: **10412132025** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: **HS-13b Lunchroom East** Lab ID: **10412132026** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
BFS Left

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:38	7439-92-1	

Sample: **HS-14a Lunchroom East** Lab ID: **10412132027** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
DWC R

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:42	7439-92-1	

Sample: **HS-14b Lunchroom East** Lab ID: **10412132028** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
DWC R

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:43	7439-92-1	

Sample: **HS-15a Lunchroom East** Lab ID: **10412132029** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
BFS R

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:45	7439-92-1	

Sample: **HS-15b Lunchroom East** Lab ID: **10412132030** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
BFS R

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: HS-16a Kitchen Sink		Lab ID: 10412132031		Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water	
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.17	ug/L	0.10	0.010	1		12/05/17 21:47	7439-92-1	
Sample: HS-16b Kitchen Sink		Lab ID: 10412132032		Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water	
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:50	7439-92-1	
Sample: HS-17a Teacher's LunchroomSink		Lab ID: 10412132033		Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water	
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.59	ug/L	0.10	0.010	1		12/05/17 21:51	7439-92-1	
Sample: HS-17b Teacher's LunchroomSink		Lab ID: 10412132034		Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water	
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:52	7439-92-1	
Sample: HS-18a Corridor 1 DWC Left		Lab ID: 10412132035		Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water	
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: **HS-18b Corridor 1 DWC Left** Lab ID: **10412132036** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 21:59	7439-92-1	

Sample: **HS-19a Corridor 1 BFS** Lab ID: **10412132037** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 22:00	7439-92-1	

Sample: **HS-19b Corridor 1 BFS** Lab ID: **10412132038** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 22:01	7439-92-1	

Sample: **HS-20a Corridor 1 DWC Right** Lab ID: **10412132039** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 22:03	7439-92-1	

Sample: **HS-20b Corridor 1 DWC Right** Lab ID: **10412132040** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	0.39	ug/L	0.10	0.010	1		12/05/17 22:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: HS-21a Corridor 20 DWC Lab ID: 10412132041 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
Left

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.12	ug/L	0.10	0.010	1		12/01/17 19:27	7439-92-1	

Sample: HS-21b Corridor 20 DWC Lab ID: 10412132042 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
Left

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.39	ug/L	0.10	0.010	1		12/01/17 19:36	7439-92-1	

Sample: HS-22a Corridor 20 DWC Lab ID: 10412132043 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
Right

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	0.010	1		12/01/17 19:41	7439-92-1	

Sample: HS-22b Corridor 20 DWC Lab ID: 10412132044 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
Right

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	0.010	1		12/01/17 19:42	7439-92-1	

Sample: HS-23a Corridor 20 BFS Lab ID: 10412132045 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	0.010	1		12/01/17 19:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: HS-23b Corridor 20 BFS		Lab ID: 10412132046	Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water		
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8
Lead ND ug/L 0.10 0.010 1 12/01/17 19:45 7439-92-1

Sample: HS-24a Corridor 17 DWC Left		Lab ID: 10412132047	Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water		
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8
Lead 0.19 ug/L 0.10 0.010 1 12/01/17 19:46 7439-92-1

Sample: HS-24b Corridor 17 DWC Left		Lab ID: 10412132048	Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water		
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8
Lead 0.61 ug/L 0.10 0.010 1 12/01/17 19:48 7439-92-1

Sample: HS-25a Corridor 17 DWC Right		Lab ID: 10412132049	Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water		
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8
Lead ND ug/L 0.10 0.010 1 12/01/17 19:49 7439-92-1

Sample: HS-25b Corridor 17 DWC Right		Lab ID: 10412132050	Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water		
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8
Lead ND ug/L 0.10 0.010 1 12/01/17 19:50 7439-92-1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: HS-26a Corridor 17 BFS Lab ID: 10412132051 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	-----	----	----------	----------	---------	------

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	ND	ug/L	0.10	0.010	1		12/01/17 19:51	7439-92-1	
------	----	------	------	-------	---	--	----------------	-----------	--

Sample: HS-26b Corridor 17 BFS Lab ID: 10412132052 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	-----	----	----------	----------	---------	------

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	ND	ug/L	0.10	0.010	1		12/01/17 19:58	7439-92-1	
------	----	------	------	-------	---	--	----------------	-----------	--

Sample: HS-27a Basement Corridor DW L Lab ID: 10412132053 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	-----	----	----------	----------	---------	------

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	ND	ug/L	0.10	0.010	1		12/01/17 19:59	7439-92-1	
------	----	------	------	-------	---	--	----------------	-----------	--

Sample: HS-27b Basement Corridor DW L Lab ID: 10412132054 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	-----	----	----------	----------	---------	------

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	ND	ug/L	0.10	0.010	1		12/01/17 20:01	7439-92-1	
------	----	------	------	-------	---	--	----------------	-----------	--

Sample: HS-28a Basement Corridor BFS L Lab ID: 10412132055 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	-----	----	----------	----------	---------	------

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	ND	ug/L	0.10	0.010	1		12/01/17 20:02	7439-92-1	
------	----	------	------	-------	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: **HS-28b Basement Corridor** Lab ID: **10412132056** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
BFS L

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/01/17 20:03	7439-92-1	

Sample: **HS-29a Basement Corridor** Lab ID: **10412132057** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
DWC R

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/01/17 20:04	7439-92-1	

Sample: **HS-29b Basement Corridor** Lab ID: **10412132058** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
DWC R

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/01/17 20:06	7439-92-1	

Sample: **HS-30a Basement Corridor** Lab ID: **10412132059** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
BFS R

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/01/17 20:07	7439-92-1	

Sample: **HS-30b Basement Corridor** Lab ID: **10412132060** Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water
BFS R

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/01/17 20:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: HS-31a Corridor 14 DWC West Lab ID: 10412132061 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 16:49	7439-92-1	

Sample: HS-31b Corridor 14 DWC West Lab ID: 10412132062 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 16:54	7439-92-1	

Sample: HS-32a Corridor 14 BFS Lab ID: 10412132063 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 16:56	7439-92-1	

Sample: HS-32b Corridor 14 BFS Lab ID: 10412132064 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 16:57	7439-92-1	

Sample: HS-33a Corridor 14 DWC East Lab ID: 10412132065 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 16:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: HS-33b Corridor 14 DWC East Lab ID: 10412132066 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 16:59	7439-92-1	

Sample: HS-34a Gym BFS Lab ID: 10412132067 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 17:05	7439-92-1	

Sample: HS-34b Gym BFS Lab ID: 10412132068 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 17:06	7439-92-1	

Sample: HS-35a Corridor 11 DWC Left Lab ID: 10412132069 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 17:07	7439-92-1	

Sample: HS-35b Corridor 11 DWC Left Lab ID: 10412132070 Collected: 11/16/17 05:00 Received: 11/22/17 11:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8									
Lead	ND	ug/L	0.10	0.010	1		12/05/17 17:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Sample: HS-36a Corridor 11 BFS		Lab ID: 10412132071	Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water		
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8
Lead ND ug/L 0.10 0.010 1 12/05/17 17:10 7439-92-1

Sample: HS-36b Corridor 11 BFS		Lab ID: 10412132072	Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water		
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8
Lead ND ug/L 0.10 0.010 1 12/05/17 17:12 7439-92-1

Sample: HS-37a Corridor 11 DWC Right		Lab ID: 10412132073	Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water		
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8
Lead ND ug/L 0.10 0.010 1 12/05/17 17:13 7439-92-1

Sample: HS-37b Corridor 11 DWC Right		Lab ID: 10412132074	Collected: 11/16/17 05:00		Received: 11/22/17 11:30		Matrix: Water		
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8
Lead ND ug/L 0.10 0.010 1 12/05/17 17:15 7439-92-1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

QC Batch: 510476 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10412132001, 10412132002, 10412132003, 10412132004, 10412132005, 10412132006, 10412132007, 10412132008, 10412132009, 10412132010, 10412132011, 10412132012, 10412132013, 10412132014, 10412132015, 10412132016, 10412132017, 10412132018, 10412132019, 10412132020

METHOD BLANK: 2776065 Matrix: Water
Associated Lab Samples: 10412132001, 10412132002, 10412132003, 10412132004, 10412132005, 10412132006, 10412132007, 10412132008, 10412132009, 10412132010, 10412132011, 10412132012, 10412132013, 10412132014, 10412132015, 10412132016, 10412132017, 10412132018, 10412132019, 10412132020

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	0.010	11/30/17 23:02	

LABORATORY CONTROL SAMPLE: 2776066

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	102	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2780391 2780392

Parameter	Units	10412132001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	Max RPD	Qual
Lead	ug/L	ND	100	100	97.0	96.2	97	96	70-130	1 20	

MATRIX SPIKE SAMPLE: 2780393

Parameter	Units	10412132011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	0.61	100	96.9	96	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

QC Batch: 510478 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10412132021, 10412132022, 10412132023, 10412132024, 10412132025, 10412132026, 10412132027, 10412132028, 10412132029, 10412132030, 10412132031, 10412132032, 10412132033, 10412132034, 10412132035, 10412132036, 10412132037, 10412132038, 10412132039, 10412132040

METHOD BLANK: 2776068 Matrix: Water
Associated Lab Samples: 10412132021, 10412132022, 10412132023, 10412132024, 10412132025, 10412132026, 10412132027, 10412132028, 10412132029, 10412132030, 10412132031, 10412132032, 10412132033, 10412132034, 10412132035, 10412132036, 10412132037, 10412132038, 10412132039, 10412132040

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	0.010	12/05/17 21:27	

LABORATORY CONTROL SAMPLE: 2776069

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	94.5	94	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2784120 2784121

Parameter	Units	10412132021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	Max RPD	Qual
Lead	ug/L	ND	100	100	93.6	93.4	94	93	70-130	0	20

MATRIX SPIKE SAMPLE: 2784122

Parameter	Units	10412132031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	0.17	100	96.0	96	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

QC Batch: 510479 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10412132041, 10412132042, 10412132043, 10412132044, 10412132045, 10412132046, 10412132047, 10412132048, 10412132049, 10412132050, 10412132051, 10412132052, 10412132053, 10412132054, 10412132055, 10412132056, 10412132057, 10412132058, 10412132059, 10412132060

METHOD BLANK: 2776071 Matrix: Water
Associated Lab Samples: 10412132041, 10412132042, 10412132043, 10412132044, 10412132045, 10412132046, 10412132047, 10412132048, 10412132049, 10412132050, 10412132051, 10412132052, 10412132053, 10412132054, 10412132055, 10412132056, 10412132057, 10412132058, 10412132059, 10412132060

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	0.010	12/01/17 19:25	

LABORATORY CONTROL SAMPLE: 2776072

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	99.9	100	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2781645 2781646

Parameter	Units	10412132041 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	Max RPD	Qual
Lead	ug/L	0.12	100	100	104	91.7	104	92	70-130	12	20

MATRIX SPIKE SAMPLE: 2781647

Parameter	Units	10412132051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	ND	100	105	105	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

QC Batch: 510538 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10412132061, 10412132062, 10412132063, 10412132064, 10412132065, 10412132066, 10412132067, 10412132068, 10412132069, 10412132070, 10412132071, 10412132072, 10412132073, 10412132074

METHOD BLANK: 2776303 Matrix: Water
Associated Lab Samples: 10412132061, 10412132062, 10412132063, 10412132064, 10412132065, 10412132066, 10412132067, 10412132068, 10412132069, 10412132070, 10412132071, 10412132072, 10412132073, 10412132074

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	0.010	12/05/17 16:34	

LABORATORY CONTROL SAMPLE: 2776304

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	105	105	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2783991 2783992

Parameter	Units	10412132061 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	Max RPD	Qual
Lead	ug/L	ND	100	100	87.4	94.9	87	95	70-130	8 20	

MATRIX SPIKE SAMPLE: 2783993

Parameter	Units	10412132071 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	ND	100	93.6	94	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.
ND - Not Detected at or above adjusted reporting limit.
TNTC - Too Numerous To Count
J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.
MDL - Adjusted Method Detection Limit.
PQL - Practical Quantitation Limit.
RL - Reporting Limit.
S - Surrogate
1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.
Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.
LCS(D) - Laboratory Control Sample (Duplicate)
MS(D) - Matrix Spike (Duplicate)
DUP - Sample Duplicate
RPD - Relative Percent Difference
NC - Not Calculable.
SG - Silica Gel - Clean-Up
U - Indicates the compound was analyzed for, but not detected.
N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.
Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.
TNI - The NELAC Institute.

LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10412132001	HS-01a First Floor Office DWC	EPA 200.8	510476		
10412132002	HS-01b First Floor Office DWC	EPA 200.8	510476		
10412132003	HS-02a First Floor Office BFS	EPA 200.8	510476		
10412132004	HS-02b First Floor Office BFS	EPA 200.8	510476		
10412132005	HS-03a Corridor 10 DWC Left	EPA 200.8	510476		
10412132006	HS-03b Corridor 10 DWC Left	EPA 200.8	510476		
10412132007	HS-04a Corridor 10 DWC BFS	EPA 200.8	510476		
10412132008	HS-04b Corridor 10 DWC BFS	EPA 200.8	510476		
10412132009	HS-05a Corridor 10 DWC Right	EPA 200.8	510476		
10412132010	HS-05b Corridor 10 DWC Right	EPA 200.8	510476		
10412132011	HS-06a Classroom 144 Sink	EPA 200.8	510476		
10412132012	HS-06b Classroom 144 Sink	EPA 200.8	510476		
10412132013	HS-07a Classroom 145 Sink	EPA 200.8	510476		
10412132014	HS-07b Classroom 145 Sink	EPA 200.8	510476		
10412132015	HS-08a Classroom 147 Sink	EPA 200.8	510476		
10412132016	HS-08b Classroom 147 Sink	EPA 200.8	510476		
10412132017	HS-09a Lunchroom West DWC Left	EPA 200.8	510476		
10412132018	HS-09b Lunchroom West DWC Left	EPA 200.8	510476		
10412132019	HS-10a Lunchroom West DWC R	EPA 200.8	510476		
10412132020	HS-10b Lunchroom West DWC R	EPA 200.8	510476		
10412132021	HS-11a Lunchroom West BFS	EPA 200.8	510478		
10412132022	HS-11b Lunchroom West BFS	EPA 200.8	510478		
10412132023	HS-12a Lunchroom East DWC Left	EPA 200.8	510478		
10412132024	HS-12b Lunchroom East DWC Left	EPA 200.8	510478		
10412132025	HS-13a Lunchroom East BFS Left	EPA 200.8	510478		
10412132026	HS-13b Lunchroom East BFS Left	EPA 200.8	510478		
10412132027	HS-14a Lunchroom East DWC R	EPA 200.8	510478		
10412132028	HS-14b Lunchroom East DWC R	EPA 200.8	510478		
10412132029	HS-15a Lunchroom East BFS R	EPA 200.8	510478		
10412132030	HS-15b Lunchroom East BFS R	EPA 200.8	510478		
10412132031	HS-16a Kitchen Sink	EPA 200.8	510478		
10412132032	HS-16b Kitchen Sink	EPA 200.8	510478		
10412132033	HS-17a Teacher's LunchroomSink	EPA 200.8	510478		
10412132034	HS-17b Teacher's LunchroomSink	EPA 200.8	510478		
10412132035	HS-18a Corridor 1 DWC Left	EPA 200.8	510478		
10412132036	HS-18b Corridor 1 DWC Left	EPA 200.8	510478		
10412132037	HS-19a Corridor 1 BFS	EPA 200.8	510478		
10412132038	HS-19b Corridor 1 BFS	EPA 200.8	510478		
10412132039	HS-20a Corridor 1 DWC Right	EPA 200.8	510478		
10412132040	HS-20b Corridor 1 DWC Right	EPA 200.8	510478		
10412132041	HS-21a Corridor 20 DWC Left	EPA 200.8	510479		
10412132042	HS-21b Corridor 20 DWC Left	EPA 200.8	510479		
10412132043	HS-22a Corridor 20 DWC Right	EPA 200.8	510479		
10412132044	HS-22b Corridor 20 DWC Right	EPA 200.8	510479		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: 1798590-01 S.D. #41-Hadley Jr
Pace Project No.: 10412132

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10412132045	HS-23a Corridor 20 BFS	EPA 200.8	510479		
10412132046	HS-23b Corridor 20 BFS	EPA 200.8	510479		
10412132047	HS-24a Corridor 17 DWC Left	EPA 200.8	510479		
10412132048	HS-24b Corridor 17 DWC Left	EPA 200.8	510479		
10412132049	HS-25a Corridor 17 DWC Right	EPA 200.8	510479		
10412132050	HS-25b Corridor 17 DWC Right	EPA 200.8	510479		
10412132051	HS-26a Corridor 17 BFS	EPA 200.8	510479		
10412132052	HS-26b Corridor 17 BFS	EPA 200.8	510479		
10412132053	HS-27a Basement Corridor DWC L	EPA 200.8	510479		
10412132054	HS-27b Basement Corridor DWC L	EPA 200.8	510479		
10412132055	HS-28a Basement Corridor BFS L	EPA 200.8	510479		
10412132056	HS-28b Basement Corridor BFS L	EPA 200.8	510479		
10412132057	HS-29a Basement Corridor DWC R	EPA 200.8	510479		
10412132058	HS-29b Basement Corridor DWC R	EPA 200.8	510479		
10412132059	HS-30a Basement Corridor BFS R	EPA 200.8	510479		
10412132060	HS-30b Basement Corridor BFS R	EPA 200.8	510479		
10412132061	HS-31a Corridor 14 DWC West	EPA 200.8	510538		
10412132062	HS-31b Corridor 14 DWC West	EPA 200.8	510538		
10412132063	HS-32a Corridor 14 BFS	EPA 200.8	510538		
10412132064	HS-32b Corridor 14 BFS	EPA 200.8	510538		
10412132065	HS-33a Corridor 14 DWC East	EPA 200.8	510538		
10412132066	HS-33b Corridor 14 DWC East	EPA 200.8	510538		
10412132067	HS-34a Gym BFS	EPA 200.8	510538		
10412132068	HS-34b Gym BFS	EPA 200.8	510538		
10412132069	HS-35a Corridor 11 DWC Left	EPA 200.8	510538		
10412132070	HS-35b Corridor 11 DWC Left	EPA 200.8	510538		
10412132071	HS-36a Corridor 11 BFS	EPA 200.8	510538		
10412132072	HS-36b Corridor 11 BFS	EPA 200.8	510538		
10412132073	HS-37a Corridor 11 DWC Right	EPA 200.8	510538		
10412132074	HS-37b Corridor 11 DWC Right	EPA 200.8	510538		

REPORT OF LABORATORY ANALYSIS


This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A				Section B				Section C				
Required Client Information:				Required Project Information:				Invoice Information:				
Company:		United Analytical Services, Inc. (UAS)		Report To:		Thad Daniels		Attention:		Same		
Address:		1429 Centre Circle Drive		Copy To:				Company Name:		Same		
Dowens Grove, Illinois 60515				Purchase Order #:				Address:		Same		
Email: tdaniels@uas1.com				Project Name:		S.D. #41 - Hadley Junior High School		Pace Order:		40881		
Phone: 630-891-8271		Fax: 630-891-1819		Project #:		1758590-01		Pace Project Manager:		Jeff Dutton		
Requested Due Date:		Standard TAT		Matrix Code (see valid codes to left)		SAMPLE TYPE (G-ORAB G-COMP)		COLLECTED		SAMPLE TEMP AT COLLECTION		
				DATE		TIME		DATE		TIME		
				START		END						
				DATE		TIME		DATE		TIME		
ITEM #	MATRIX	CODE	SAMPLE ID	MATRIX CODE	SAMPLE TYPE	COLLECTED	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Analyses Test	Residual Chlorine (Y/N)	Requested Analysis (Y/N)
1	Drinking Water	DW	HS-07a Classroom 145 Sink	DW-G		11/16/2017 5:00a	1 X	1	None	Y		
2	Water	WT	HS-07b Classroom 145 Sink	DW-G		11/16/2017 5:00a	1 X	1		Y		
3	Waste Water	WW	HS-08a Classroom 147 Sink	DW-G		11/16/2017 5:00a	1 X	1		Y		
4	Product	P	HS-08b Classroom 147 Sink	DW-G		11/16/2017 5:00a	1 X	1		Y		
5	Salts/acid	SL	HS-09a Lunchroom West DWC Left	DW-G		11/16/2017 5:00a	1 X	1		Y		
6	Oil	OL	HS-09b Lunchroom West DWC Left	DW-G		11/16/2017 5:00a	1 X	1		Y		
7	Wax	WP	HS-10a Lunchroom West DWC Right	DW-G		11/16/2017 5:00a	1 X	1		Y		
8	Air	AR	HS-10b Lunchroom West DWC Right	DW-G		11/16/2017 5:00a	1 X	1		Y		
9	Other	OT	HS-11a Lunchroom West BFS	DW-G		11/16/2017 5:00a	1 X	1		Y		
10	Tissue	TS	HS-11b Lunchroom West BFS	DW-G		11/16/2017 5:00a	1 X	1		Y		
11			HS-12a Lunchroom East DWC Left	DW-G		11/16/2017 5:00a	1 X	1		Y		
12			HS-12b Lunchroom East DWC Left	DW-G		11/16/2017 5:00a	1 X	1		Y		
ADDITIONAL COMMENTS												
Water Last Used in School Building on: 11/15/2017 @ 8:00 p.m.												
SAMPLER NAME AND SIGNATURE												
PRINT Name of SAMPLER:												
SIGNATURE of SAMPLER:												
DATE Signed:												
11/16/2017												
TEMP in C												
Received on												
Intact (Y/N)												
Cooler (Y/N)												
Sealed (Y/N)												
Custody (Y/N)												
Samples (Y/N)												



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A				Section B				Section C									
Required Client Information:				Required Project Information:				Invoice Information:									
Company:		United Analytical Services, Inc. (UAS)		Report To:		Thad Daniels		Attention:		Same							
Address:		1429 Centre Circle Drive		Copy To:				Company Name:		Same							
Davenport Grove, Illinois 60515								Address:		Same							
Email:		tdaniels@uas1.com		Purchase Order #:		40981		Pace Project Manager:		Jeff Dutton							
Phone:		630-591-8271		Project Name:		S.D. #41 - Hadley Junior High School		Pace Profile #:		1798590-01							
Requested Due Date:		Standard TAT		Project #:		1798590-01		Regulatory Agency:		IDPH							
								State Allocation:		IL							
ITEM #	MATRIX	CODE	SAMPLE TYPE (G-ORAB C-COMP)	COLLECTED	START	END	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Arbysar Test	PB 200.6	Residual Chlorine (Y/N)	TEMP in C	Received on	Sealed	Custody	Intact
1	Drinking Water	DW	DWG		11/16/2017	5:00a	1	X					025				
2	Water	WT	DWG		11/16/2017	5:00a	1	X					026				
3	Waste Water	WW	DWG		11/16/2017	5:00a	1	X					027				
4	Product	P	DWG		11/16/2017	5:00a	1	X					028				
5	Salts/Gall	SL	DWG		11/16/2017	5:00a	1	X					029				
6	Oil	OL	DWG		11/16/2017	5:00a	1	X					030				
7	Vape	VP	DWG		11/16/2017	5:00a	1	X					031				
8	Air	AR	DWG		11/16/2017	5:00a	1	X					032				
9	Tissue	TS	DWG		11/16/2017	5:00a	1	X					033				
10	HS-16a Kitchen Sink		DWG		11/16/2017	5:00a	1	X					034				
11	HS-17a Teacher's Lunchroom Sink		DWG		11/16/2017	5:00a	1	X					035				
12	HS-18a Corridor 1 DWG Left		DWG		11/16/2017	5:00a	1	X					036				
ADDITIONAL COMMENTS																	
Water Last Used in School Building on: 11/15/2017 @ 8:00 p.m.																	
SAMPLER NAME AND SIGNATURE																	
PRINT Name of SAMPLER:																	
SIGNATURE of SAMPLER:																	
DATE Signed: 11/16/2017																	

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company:	United Analytical Services, Inc. (UAS)	Report To:	Thad Daniels	Attention:	Same
Address:	1428 Centre Circle Drive Downers Grove, Illinois 60515	Copy To:		Company Name:	Same
Email:	tdaniels@uas1.com	Purchase Order #:		Address:	Same
Phone:	630-691-8271	Project Name:	S.D. #41 - Hadley Junior High School	Pace Quote:	40881
Requested Due Date:	Standard TAT	Project #:	1798590-01	Pace Project Manager:	Jeff Dunton
				Pace Profile #:	

Page: 4 Of 7

Regulatory Agency:		IL
State Location:		

ITEM #	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		DATE	TIME	# OF CONTAINERS	Preservatives	Y/N	Analytical Test	PB 2008	Residual Chlorine (Y/N)	
			START	END									
	MATRIX CODE DW Drinking Water WW Wastewater P Product SL Solid OI Oil WP Waste Product AR Air OT Other TS Tissue		DATE	TIME	DATE	TIME							
1	HS-18a Corridor 1 BFS	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					037
2	HS-18b Corridor 1 BFS	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					038
3	HS-20a Corridor 1 DWG Right	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					039
4	HS-20b Corridor 1 DWG Right	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					040
5	HS-21a Corridor 20 DWG Left	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					041
6	HS-21b Corridor 20 DWG Left	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					042
7	HS-22a Corridor 20 DWG Right	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					043
8	HS-22b Corridor 20 DWG Right	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					044
9	HS-23a Corridor 20 BFS	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					045
10	HS-23b Corridor 20 BFS	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					046
11	HS-24a Corridor 17 DWG Left	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					047
12	HS-24b Corridor 17 DWG Left	DW/G	11/16/2017	5:00a	11/16/2017	5:00a	1	X					048

RECEIVED BY / AFFILIATION		DATE	TIME	RECEIVED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
Kattam Wendu		11/17/17	11:55	Kattam Wendu	11/17/17	11:55	
Kattam Wendu		11/20/17	12:30	Fedex	11/20/17	11:55	
Kattam Wendu		11/20/17	11:30	THA	11/20/17	11:30	
TEMP in C				Received on			
Ice (Y/N)				Sealed Cooler (Y/N)			
Custody (Y/N)				Intact Samples (Y/N)			

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	United Analytical Services, Inc. (UAS)	Report To:	Thad Daniels	Attention:	Same
Address:	1429 Centre Circle Drive	Copy To:		Company Name:	Same
	Dowenets Grove, Illinois 60515			Address:	Same
E-mail:	tdaniels@uas1.com	Purchase Order #:		Price Quote:	40981
Phone:	630-691-8271	Project Name:	S.D. #41 - Hadley Junior High School	Project Manager:	Jeff Dutton
Requested Due Date:	Standard TAT	Project #:	179559001	Price Profile #:	

[illegible]

ADDITIONAL COMMENTS	RE-INSPECTED BY AFFILIATION	DATE	TIME	ACCEPTED BY AFFILIATION	DATE	TIME	TEMP IN C	Received on	Ice (Y/N)	Custody Sealed (Y/N)	Cooler (Y/N)	Samples Intact (Y/N)
	B-3-66	11/17/17	1155	Katam Wendel	11/17/17	1155						
	Katam Wendel	11/20/17	1700	Feder	11/20/17							
				ALD	11/22/17	1130	7.9					

Water Test Used in School Building on: 11/15/2017 @ 8:00 p.m.

SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER:	Brian Grobierski
SIGNATURE of SAMPLER:	DATE Signed: 11/16/2017

Page 34 of 37



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	United Analytical Services, Inc. (UAS)	Report To:	Thad Daniels	Attention:	Same
Address:	1429 Centre Circle Drive	Copy To:		Company Name:	Same
	Davenport, Illinois 60515			Address:	Same
Email:	tdaniels@uas1.com	Purchase Order #:		Pace Quote:	40881
Phone:	630-691-8271	Project Name:	S.D. #41 - Hadley Junior High School	Pace Project Manager:	Jeff Dutton
Requested Due Date:	Standard TAT	Project #:	1798590-01	Pace Profile #:	

Page: 6 Of 7

ITEM #	MATRIX	CODE	COLLECTED		DATE	TIME	SAMPLE TYPE (G-GRAB C-COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	PRESERVATIVES	ANALYSIS TEST	Y/N	RESIDUAL CHLORINE (Y/N)	SAMPLE QUANTITY
			START	END										
1	HS-31a Corridor 14 DWG West	DW			11/16/2017	5:00a	DW/G		1	X				061
2	HS-31b Corridor 14 DWG West	WT			11/16/2017	5:00a	DW/G		1	X				062
3	HS-32a Corridor 14 BFS	WM			11/16/2017	5:00a	DW/G		1	X				063
4	HS-32b Corridor 14 BFS	P			11/16/2017	5:00a	DW/G		1	X				064
5	HS-33a Corridor 14 DWG East	SL			11/16/2017	5:00a	DW/G		1	X				065
6	HS-33b Corridor 14 DWG East	CL			11/16/2017	5:00a	DW/G		1	X				066
7	HS-34a Gym BFS	WP			11/16/2017	5:00a	DW/G		1	X				067
8	HS-34b Gym BFS	CR			11/16/2017	5:00a	DW/G		1	X				068
9	HS-35a Corridor 11 DWG Left	TS			11/16/2017	5:00a	DW/G		1	X				069
10	HS-35b Corridor 11 DWG Left				11/16/2017	5:00a	DW/G		1	X				070
11	HS-36a Corridor 11 BFS				11/16/2017	5:00a	DW/G		1	X				071
12	HS-36b Corridor 11 BFS				11/16/2017	5:00a	DW/G		1	X				072

RECEIVED BY / AFFILIATION		DATE		TIME		TEMP in C		Received on		Samples	
Kathryn Wendel		11/16/17		11:55		79		11/16/17		Intact (Y/N)	
Kathryn Wendel		11/16/17		14:30		79		11/16/17		Sealed (Y/N)	
Kathryn Wendel		11/16/17		14:30		79		11/16/17		Cooler (Y/N)	
Kathryn Wendel		11/16/17		14:30		79		11/16/17		Custody (Y/N)	
Kathryn Wendel		11/16/17		14:30		79		11/16/17		Intact (Y/N)	

Water Last Used in School Building on: 11/15/2017 @ 8:00 p.m.

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	United Analytical Services, Inc. (UAS)	Report To:	Thad Daniels	Attention:	Same
Address:	1428 Centre Circle Drive	Copy To:		Company Name:	Same
	Doverens Grove, Illinois 60515			Address:	Same
Email:	tdaniels@uas1.com	Purchase Order #:		Price Quote:	40981
Phone:	630-691-8271	Project Name:	S.D. #41 - Hadley Junior High School	Pace Project Manager:	Jeff Duntion
Requested Due Date:	Standard TAT	Project #:	1798550-01	Pace Profile #:	
Regulatory Agency:		IDPH		Site Location:	
IL					

Page: 7 Of 7

ITEM #	MATRIX CODE (see valid codes to left)	COLLECTED		SAMPLE TYPE (G-RAB C-COMP)	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	V/N	PB 200.8	Residual Chlorine (Y/N)	TEMP In C	Received on	Sealed	Cooler	Samples	
		START	END													
1	HS-37a Corridor 11 DWG Right	DATE	TIME	DATE	TIME	1	X									
2	HS-37b Corridor 11 DWG Right	DATE	TIME	DATE	TIME	1	X									
3																
4																
5																
6																
7																
8																
9																
10																
11																
12																

Water Last Used in School Building on: 11/15/2017 @ 6:00 p.m.	Signature of Sampler:	DATE Signed:
	Brian Grobetski	11/16/2017

	Document Name:	Document Revised: 30Aug2017
	Sample Condition Upon Receipt Form	Page 1 of 2
	Document No.: F-MN-L-213-rev.21	Issuing Authority: Pace Minnesota Quality Office

Sample Condition Upon Receipt	Client Name: <u>VAS</u>	Project #:
Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ SpeedDee ☐ Other:		
Tracking Number: <u>72125349 4078</u>		

Custody Seal on Cooler/Box Present? ☒ Yes ☐ No	Seals Intact? ☒ Yes ☐ No	Optional: Proj. Due Date: Proj. Name:
Packing Material: ☒ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other:	Temp Blank? ☐ Yes ☒ No	
Thermometer Used: ☐ 151401163 ☒ G87A9155100842	Type of Ice: ☐ Wet ☐ Blue ☒ None	☐ Samples on Ice, cooling process has begun
Cooler Temp Read (°C): <u>8.3</u>	Cooler Temp Corrected (°C): <u>7.9</u>	Biological Tissue Frozen? ☐ Yes ☐ No ☒ N/A
Temp should be above freezing to 6°C	Correction Factor: <u>-0.4</u>	Date and Initials of Person Examining Contents: <u>EN 11/27/17</u>
USDA Regulated Soil (☒ N/A, water sample) Old samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)? ☐ Yes ☐ No Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? ☐ Yes ☐ No		
If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.		

	COMMENTS:
Chain of Custody Present? ☒ Yes ☐ No	1.
Chain of Custody Filled Out? ☒ Yes ☐ No	2.
Chain of Custody Relinquished? ☒ Yes ☐ No	3.
Sampler Name and/or Signature on COC? ☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time? ☒ Yes ☐ No <u>11/27</u>	5.
Short Hold Time Analysis (<72 hr)? ☐ Yes ☒ No	6.
Rush Turn Around Time Requested? ☐ Yes ☒ No	7.
Sufficient Volume? ☒ Yes ☐ No	8.
Correct Containers Used? ☒ Yes ☐ No	9.
-Pace Containers Used? ☒ Yes ☐ No	
Containers Intact? ☒ Yes ☒ No <u>11/27</u>	10. <u>Cap for 25a Cracked</u>
Filtered Volume Received for Dissolved Tests? ☐ Yes ☐ No ☒ N/A	11. Note if sediment is visible in the dissolved container
Sample Labels Match COC? ☒ Yes ☐ No	12.
-Includes Date/Time/ID/Analysis Matrix: <u>WT</u>	
All containers needing acid/base preservation have been checked? ☒ Yes ☐ No ☐ N/A	13. ☒ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH Positive for Res. Chlorine? Y N
All containers needing preservation are found to be in compliance with EPA recommendation? ☒ Yes ☐ No ☐ N/A	Sample # <u>1-74: 1</u>
(HNO ₃ , H ₂ SO ₄ , <2pH, NaOH >9 Sulfide, NaOH >12 Cyanide) Exceptions: VOA, Coliform, TOC/DOC Oil and Grease, DRO/8015 (water) and Dioxin. ☐ Yes ☐ No ☒ N/A	Initial when completed: <u>JDD</u> Lot # of added preservative: <u>1117050</u>
Headspace in VOA Vials (>6mm)? ☐ Yes ☐ No ☒ N/A	14.
Trip Blank Present? ☐ Yes ☐ No ☒ N/A	15.
Trip Blank Custody Seals Present? ☐ Yes ☐ No ☒ N/A	
Pace Trip Blank Lot # (if purchased):	

CLIENT NOTIFICATION/RESOLUTION	Field Data Required? ☐ Yes ☐ No
Person Contacted:	Date/Time:
Comments/Resolution:	

Project Manager Review: <u>Alycia Hunter</u>	Date: <u>11/27/17</u>
Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e. out of hold, incorrect preservative, out of temp, incorrect containers).	



525-535 West Jefferson Street • Springfield, Illinois 62761-0001 • www.dph.illinois.gov

1/17/2017

LICENSE NUMBER: 001047

Thad Daniels

1335 Fagan Road

Batavia, IL 60510

LICENSE APPROVED

IDPH recently received and reviewed your application for lead licensure. Your qualifications have been reviewed and found that you meet the requirements set forth by the Lead Poisoning Prevention Code, Section 845.125. Therefore, your application for lead licensure is now complete. Enclosed please find your lead license card. Please have this identification card with you at all times while conducting lead abatement activities.

IDPH has updated its 7 – Day Notice of Commencement effective immediately. The revised document can be identified by its 9/16 revision date on the bottom left corner. Please discontinue using the old form and begin using the new form as soon as possible. The revised form is located in the same web address that the old form was located (<http://www.dph.illinois.gov/sites/default/files/forms/7-day-notice-leadabatement-mitigation-project-091916.pdf>).



LEAD RISK ASSESSOR LICENSE

LEAD ID	ISSUED	EXPIRES
001047	1/17/2017	1/31/2018

Thad Daniels
1335 Fagan Road
Batavia, IL 60510



ILLINOIS LEAD PROGRAM
Environmental Health

Alteration of this license shall result in legal action
RISK ASSESSOR CERTIFICATE EXPIRES

3/8/2019

This license issued under authority of the State
of Illinois -Department of Public Health


This license is valid only when accompanied by
a valid training course certificate

If found return to 525 W. Jefferson St Springfield, IL 62761

PROTECTING HEALTH, IMPROVING LIVES

Nationally Accredited by PHAB

2016



OCCUPATIONAL TRAINING & SUPPLY, INC.

7233 S. Adams Street ♦ Willowbrook, IL 60527 ♦ (630) 655-3900

Lead Risk Assessor Refresher

Occupational Training & Supply, Inc. certifies that

Thad Daniels

has successfully completed the Lead Risk Assessor Refresher course and has passed the competency exam with a minimum score of 70%.
This course is accredited by the Illinois Department of Public Health in accordance with the Illinois Lead Poisoning Prevention Code.

Course Date: 3/8/2016

Exam Date: 3/8/2016

Expiration Date: 3/8/2019

Certificate Number: LRAR1603080977

Kathy DeSalvo, Director



STATE OF ILLINOIS
ENVIRONMENTAL PROTECTION AGENCY
NELAP - RECOGNIZED
ENVIRONMENTAL LABORATORY ACCREDITATION



is hereby granted to

PACE ANALYTICAL SERVICES, LLC. - MN
1700 ELM STREET SE SUITE 200
MINNEAPOLIS, MN 55414-2485
NELAP ACCREDITED
ACCREDITATION NUMBER #200011



According to the Illinois Administrative Code, Title 35, Subtitle A, Chapter II, Part 186, ACCREDITATION OF LABORATORIES FOR DRINKING WATER, WASTEWATER AND HAZARDOUS WASTES ANALYSIS, the State of Illinois formally recognizes that this laboratory is technically competent to perform the environmental analyses listed on the scope of accreditation detailed below.

The laboratory agrees to perform all analyses listed on this scope of accreditation according to the Part 186 requirements and acknowledges that continued accreditation is dependent on successful ongoing compliance with the applicable requirements of Part 186. Please contact the Illinois EPA Environmental Laboratory Accreditation Program (IL ELAP) to verify the laboratory's scope of accreditation and accreditation status. Accreditation by the State of Illinois is not an endorsement or a guarantee of validity of the data generated by the laboratory.

Primary Accrediting Authority: MN Department of Health, ELAP

Celeste M. Crowley
Supervisor
Environmental Laboratory Accreditation Program

John South
Accreditation Officer
Environmental Laboratory Accreditation Program

Certificate No.: 003998
Expiration Date: 12/11/2017
Issued On: 11/15/2016

State of Illinois
Environmental Protection Agency
Awards the Certificate of Approval

Certificate No.: 003998

Pace Analytical Services, LLC. - MN
1700 Elm Street SE Suite 200
Minneapolis, MN 55414-2485

FOT Name: Drinking Water, Inorganic

Method: SM4500P-E,20Ed

Matrix Type: Potable Water

Orthophosphate

Method: USEPA180.1

Matrix Type: Potable Water

Turbidity

Method: USEPA200.8R5.4

Matrix Type: Potable Water

Aluminum

Antimony

Arsenic

Barium

Beryllium

Cadmium

Chromium

Copper

Lead

Manganese

Mercury

Nickel

Selenium

Silver

Thallium

Zinc

Method: USEPA245.1R3.0

Matrix Type: Potable Water

Mercury

Method: USEPA300.0R2.1

Matrix Type: Potable Water

Bromide

Chloride

Fluoride

Nitrate

Nitrite

Sulfate

Method: USEPA353.2R2.0

Matrix Type: Potable Water

Nitrate

Nitrite

FOT Name: Drinking Water, Organic

Method: USEPA1613RB

Matrix Type: Potable Water

Dioxin (2,3,7,8 TCDD)

Method: USEPA524.2R4.1

Matrix Type: Potable Water

1,1,1,2-Tetrachloroethane

1,1,1-Trichloroethane

1,1,2,2-Tetrachloroethane

1,1,2-Trichloroethane

1,1-Dichloroethane

1,1-Dichloroethene



Mitigation Strategies

for Lead Found in
School Drinking Water

Guidance Document for Mitigating Lead in Schools



New Guidance

Pursuant to the Illinois Plumbing Licensing Law (225 ICLS 320/35.5), the Illinois Department of Public Health (IDPH) is required to provide guidance to schools concerning mitigation of hazards discovered by testing for lead in water.

While Section 35.5 does not specifically require mitigation, IDPH is requiring the mitigation strategies and requirements contained in this guidance document to be followed for all plumbing fixtures identified with any level of lead. Mitigation should continue until subsequent testing indicates no lead is present in water.

Mitigation strategies depend on many variables and schools may need to implement various and multiple steps to mitigate lead-in-water hazards. This guidance provides the most common mitigations strategies, but is not intended to be all inclusive.

WQMP

Water Quality Management Plan

Steps to an Effective Water Quality Management Plan

Regardless of lead or any other potential plumbing issues within your facility, developing an effective Water Quality Management Plan (WQMP) is essential to ensuring that safe, potable drinking water is maintained at all times.

In many cases, the internal plumbing system in schools and other large facilities is extensive, often containing hundreds, if not thousands of feet of pipe. If left unused for extended periods of time (2-3 days), the water in this pipe can become stagnant and develop internal water quality issues such as high lead concentrations and harmful bacterial growth.

An effective WQMP can help mitigate the potential for these negative water quality issues.

The steps outlined in this section are not intended to be all inclusive, since every facility and administration is different, each with their own set of individual circumstances. However, it should help you understand the general concepts of a WQMP and how you can develop your unique team to address potential water quality conditions within your facility.

Step 1


Select Your Team

Your team could include:

- Administrators and Faculty
- Facilities and Maintenance Staff
- Parents
- Students
- Water Suppliers

These individuals will be key to implementing whatever program you develop.

- In general terms, familiarize yourself with the layout of your plumbing system. Look for long pipe runs with fixtures that may be used infrequently, even when the building is occupied.



Step 2

Understand Your Facility Layout

- Obtain building plans.
- Know where your drinking fountains and food service water fixtures are located.

Step 3

Understand Your Facility Schedule

Although this step will be intuitive for facility staff, you should familiarize your team with the schedule of the facility. Questions to ask include:

- When is the facility closed for more than just one day?
 - Weekends, holidays, extended spring or summer break periods.

- Are there any particular areas of the building that are unused even when the rest of the facility is operational? These may include:
 - Gymnasiums
 - Churches or rectories
 - Childcare areas
 - Particular classroom areas or wings of the building.

Step 4

Develop Your Plan

The principal goal of your plan will be to flush an adequate amount of water through your plumbing system in order to maintain fresh (safe) drinking water at all times, in all areas of your facility. In addition, you want to do this without unnecessarily wasting water.

Flushing is the easiest method whereby fresh water may be delivered from the water main. Because lead concentrations increase the longer the water is in contact with pipes or plumbing fixtures containing lead, reducing the water age (how long water sits in the pipe) will reduce the levels of lead in water.

Note: IDPH suggests the following program guidelines be considered as minimum steps:

1. *Locate the fixtures farthest from the entry point of the water service to the building and flush them for 10 minutes each morning.*
2. *Open all fixtures used for cooking and drinking and run until you feel the water temperature get colder.*

Additional information on flushing and other remedies is available in the U.S. Environmental Protection Agency's 3Ts for Reducing Lead in Drinking Water In Schools Technical Guidance.

Schools can request help from their supplier in identifying potential lead hazards and developing mitigation strategies. The water supplier can also educate the school on topics like corrosion control and water age.

Schools on well water or non-community water systems, can request help from the Illinois Section American Water Works Association (AWWA) or the Illinois Rural Water Association.

Your plan may likely include some if not all of these actions:

Mechanical Flushing requires the installation of devices such as valves or other similar equipment on the ends of long pipes that can be set to automatically flush at pre-determined intervals.

Licensed plumbers and engineers can help determine the type of device that should be installed and where to install the device.

Manual Flushing will likely require a variety of individuals to implement.

Faculty - Faculty members may be able to flush fixtures (sinks, drinking fountains, etc.) if they are nearby or in their classroom or work area.

Parents - Parent volunteers may be helpful in flushing fixtures in general areas or in organizing student volunteers to help with that job.

Students - Faculty and school administrators often are interested in providing students with additional responsibilities outside the classroom. Utilizing students to assist in the implementation of your WQMP can help teach them responsibility and better understand the importance of safe drinking water.

- **Develop a Student Water Patrol**

Select a handful of students whom you believe are deserving of responsibility.

If you have a public water utility, engage those professionals to explain the importance of safe drinking water and how the students can help protect their classmates by participating in a Student Water Patrol.

Step 5

Implement Your Plan

Remove the problem fixture(s) from service


Immediately upon learning that a fixture has tested positive for lead, it should be removed from service. *Install signs, remove handles or bag the device to prevent use until it can be addressed.*



Once the fixture has been addressed, validation testing is required and should be conducted in the same manner in which the initial testing was performed.

Persistent Problem Fixtures

- For sources of water that are not corrected by the steps outlined previously, infrastructure mitigation strategies may be required.
- Source investigation involves sequential sampling of the problem fixture to determine the relative location of the source of lead. Sequential sampling consists of a series of samples taken at defined time intervals from a single fixture.
- A plumbing survey, including a determination of installed plumbing materials, fixtures and length of pipes, should be developed to identify known and possible sources.
- Permanent removal of fixtures and branch plumbing should only be undertaken with the advice of a professional engineer or licensed plumber. Identified sources of lead, such as lead pipes, leaded plumbing fixtures and lead solder, should be replaced by a registered plumbing contractor with materials that do not contain lead.
- Automatic flushing valves, installed by a licensed plumber, may be implemented to ensure adequate flushing of piping systems.





Working Together ... Administration, Faculty, Students, Parents
and Water Professionals we can...

GET THE LEAD OUT !

* Illinois Section AWWA email: jdillon@isawwa.org

* Illinois Rural Water Association email: ilrwa@ilrwa.org

*Questions regarding lead in schools should be directed to the:
Illinois Department of Public Health
Plumbing and Water Quality Program*

Email: dph.leadh2o@illinois.gov